

ADDENDUM #1

KITSAP COUNTY PUBLIC WORKS WASTEWATER DIVISION SILVERDALE CONVEYANCE SYSTEM AND PUMP STATION 4 UPGRADES

TO: All Respondents
FROM: Glenn McNeill, Buyer
CLOSING DATE: April 20, 2023 at 3:00 p.m.
REF: Formal Bid Contract 2023-019
DATE: April 14, 2023

The purpose of this addendum is to modify the Contract Documents for the referenced project. This addendum shall become a part of these Contract Documents. Bidder shall acknowledge receipt of this 5-page addendum (including attachments) on the bid form.

VOLUME 1 OF 3 OF THE CONTRACT DOCUMENTS IS MODIFIED AS FOLLOWS:

INVITATION TO BID

Item 1. ADD the attached Mandatory Pre-Bid Meeting Attendance List to the Contract Documents. This list supplements the Pre-Bid Sign-in Sheet included in the Bid Documents.

SECTION 1-02.1(2) Supplemental Bidder Responsibility Criteria

Item 2. REVISE the second paragraph of Section 1-02.1(2) Supplemental Bidder Responsibility to read as follows:

For purposes of meeting this criterion, the Contracting Agency has determined that "similar size and scope" means municipal public works projects that include the following: pump station installations and/or upgrades with a minimum capacity of 1,000 gpm and at least 2,000 feet of gravity sewer and/or sewer force main with diameters of at least 12 inches. ~~The following shall be included in the referenced projects:~~

1. Pump Stations, all of the following shall be included on each project:
 - a. Constructing new buildings or modifying existing buildings.
 - b. Constructing a new wet well.
 - c. Installing new and/or replacing existing piping and valves.
 - d. Installing new and/or replacing existing power, control, and telemetry panels.
 - e. Installing a new generator, ~~and~~
 - f. Bypass operations that require bypassing a minimum of 1,000 gpm.
 - g. Pumping capacity of the facilities shall be at least 1,000 gpm.

2. Pipelines
 - a. Installing new pipe within residential streets and/or arterials (at least one of the projects shall involve ~~involving~~ construction within an arterial street.
 - b. Installing new manholes.
 - c. Extending new side sewers and connecting said to existing side sewers.
 - d. HMA patch and overlay.
 - e. Connections to existing systems.
 - f. Experience shall include at least 2,000 feet of gravity sewers with a minimum diameter of 12-inches.
 - g. Experience shall include at least 2,000 feet of sewer force main or water main with a minimum diameter of 12 inches.

SECTION 26 22 13 LOW-VOLTAGE DISTRIBUTION TRANSFORMERS

Item 3. REVISE Section 26 22 13 Low-Voltage Distribution Transformers: Add the following manufacturer as the last sentence of paragraph 2.01.A.1.

G. ABB (Formerly General Electric)

SECTION 26 24 13 SWITCHBOARDS

Item 4. REVISE Section 26 24 13 Switchboards: Revise the list of allowable manufacturers in Paragraph 1.01B.1c to read, "NEMA 1 or 12 overall enclosure".

Item 5. REVISE Section 26 24 13 Switchboards: Revise the list of allowable manufacturers in Paragraph 2.01.A to read as follows:

1. Square D; a brand of Schneider Electric.
2. Eaton Electrical Inc.; (formerly Cutler-Hammer).
3. ABB (formerly General Electric).
4. Siemens.

SECTION 26 24 16 PANELBOARDS

Item 6. REVISE Section 26 24 16 Panelboards: Add the following manufacturer as the last sentence of paragraph 2.03.A.1.

d. ABB (formerly General Electric)

Item 7. REVISE Section 26 24 16 Panelboards: Add the following manufacturer as the last sentence of paragraph 2.04.A.1.

d. ABB (formerly General Electric)

Item 8. REVISE Section 26 24 16 Panelboards: Add the following manufacturer as the last sentence of paragraph 2.05.A.1.

d. ABB (formerly General Electric)

Item 9. REVISE Section 26 24 16 Panelboards: Add the following manufacturer as the last sentence of paragraph 2.06.A.1.

d. ABB (formerly General Electric)

SECTION 26 24 19 MOTOR-CONTROL CENTERS

Item 10. REVISE Section 26 24 19 Motor Control Centers: Add the following manufacturer as the last sentence of paragraph 2.01. A.1.

d. ABB (formerly General Electric)

SECTION 26 28 16 ENCLOSED CIRCUIT BREAKERS

Item 11. REVISE Section 26 28 16 Enclosed Circuit Breakers: Add the following manufacturer as the last sentence of paragraph 2.01.A.1.

d. ABB (formerly General Electric)

SECTION 26 29 13 MOTOR CONTROL EQUIPMENT

Item 12. REVISE Section 26 29 13 Motor Control Equipment: Add the following manufacturer as the last sentence of paragraph 2.01.A.1.

d. ABB (formerly General Electric)

SECTION 26 29 13.13 ACROSS-THE-LINE MOTOR CONTROLLERS

Item 13. REVISE Section 26 29 13.13 Across-the-Line Motor Controllers: Add the following manufacturer as the last sentence of paragraph 2.01.C

d. ABB (formerly General Electric)

SECTION 26 29 13.56 MOTOR CONTROLLER OVERLOAD RELAY

Item 14. REVISE Section 26 29 13.56 Motor Controller Overload Relay: Add the following manufacturer as the last sentence of paragraph 2.01.C

d. ABB (formerly General Electric)

SECTION 26 36 23 AUTOMATIC TRANSFER SWITCHES (ATS)

Item 15. REVISE Section 26 36 23 Automatic Transfer Switches (ATS): Add the following manufacturer as the last sentence of paragraph 2.01.A

d. ABB (formerly General Electric)

SECTION 40 61 13 Process Control System General Provisions

Item 16. REVISE 40 61 13 Process Control System General Provisions: Revise the following Systems Integrator list paragraph, 40 61 13 1.03E to read as follows:

E. All fabrication, assembly, testing, and servicing for this project shall be performed through a listed firm's office within 100 miles of the project work

site. All protocol converter, PLC, and operator interface services including programming, configuration, and field servicing must be performed by a full-time employee of the business location within 100 miles of the project work site. The Contractor shall select one System Integrator from the following acceptable companies.

1. Quality Controls - Lynnwood, Washington
2. Technical Systems, Inc. - Lynnwood, Washington
3. Taurus Power & Controls, Inc. – Kent, Washington

ATTACHMENTS FOR ADDENDUM #1

Item 17. Mandatory Pre-Bid Meeting Attendance List

End of Addendum #1

