



ADDENDUM #2

INFORMAL BID 2018-126 CENTRAL KITSAP TREATMENT PLANT PROCESS BUILDING HVAC REPLACEMENT

TO: All Respondents
FROM: Colby Wattling
CLOSING DATE: April 24, 2018 at 3:00 PM (UNCHANGED)
REF NO.: 2018-126 IFB
DATE: April 16, 2018

The purpose of this addendum is to modify the Contract Documents for the referenced project. This addendum shall become a part of these Contract Documents. Bidder shall acknowledge receipt of this addendum on the Bid Form.

INVITATION TO BID

Item 1. ADD the attached Pre-Bid Meeting Attendance List to the Contract Documents.

SCOPE OF WORK:

Item 2. ADD the following Scope of Work item:

13. At Process Building upper roof install existing lightning arrester system on new HVAC unit and reconnect to existing rooftop grounding system, see attached photograph for partial picture of existing unit. Reinstallation is not required to be certified.

- Item 3. REPLACE Scope of Work Item **4. Packaged Unit Controls Interface** in its entirety with the following:
- a. Replace existing thermostatic controls with new. New thermostats to be 7-day programmable for heat and cooling. No manufacturer's proprietary thermostats allowed.
 - b. Battery powered thermostats are not allowed.
 - c. Units shall be provided with damper actuators to control the economizer.

Attachments For:

- Item 1. Pre-Bid Meeting Attendance List
- Item 2. Partial picture of existing lightning arrester system.

End Addendum #2